

Fire Extinguisher Requirements - Helicopter

NFPA 418

Helicopter Category	Helicopter Overall Length	Minimum Rating
H-1	Less than 50ft	4-a:80-B
H-2	50ft up to but not including 80ft	10-A:120-B
H-3	80ft up to but not including 120ft	30-A:240-B

***Helicopter length, including the tail boom and rotors**

9.1 General. The selection, installation, and maintenance of

portable fire extinguishers shall comply with NFPA 10.

9.2 Minimum Requirement. At least one portable fire extinguisher as specified in Table 9.2 shall be provided for each takeoff and landing area, parking area, and fuel storage area.