

# Owner's Inspection

## Kitchen Monthly Quick Check

At a minimum, the inspection shall include verification of the following:

- (1) The extinguishing system is in its proper location.
- (2) The manual actuators are unobstructed.
- (3) The tamper indicators and seals are intact.
- (4) The maintenance tag or certificate is in place.
- (5) No obvious physical damage or condition exists that might prevent operation.
- (6) The pressure gauge(s), if provided, has been inspected physically or electronically to ensure it is in the operable range.
- (7) The nozzle blowoff caps, where provided, are intact and undamaged.
- (8) The hazard has not changed, including replacement, modification, and relocation of protected equipment.

**NFPA 17A Chapter 8, Section 8.2.2**